

Attestation

BREEAM®

On 25 February 2020, Eurofins Product Testing A/S received a sample of a wood based panel with the product name:

IXTEX (tipo XQR)

supplied by

ILCAM Spa

The sample was supplied as being representative of the manufactured product, and it has been tested as in accordance with the relevant EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 testing standards (See test report no. 392-2020-00097201_I_EN_rev1).

The test results of the tested sample indicate that the product qualifies for the below mentioned BREEAM specifications on VOC emissions by complying with:

- **BREEAM® NOR: Compliance with Exemplary criteria on VOC emission** of BREEAM NOR: New Construction 2022, Technical Manual - SD5076NOR, Hea 02 Indoor Air Quality (version 6.0 of February 2022).

8 June 2022